

BOARD OF DIRECTORS MEETING JANUARY 19, 2012
ADDENDUM TO GENERAL MANAGER'S REPORT
WASTEWATER SUPERVISOR REPORT

- 1) Hydro vac/cleaned Lift Station #8.
- 2) Installed new 240V/120V transformer at Lift Station #4.
- 3) Working on revising Cambria CSD Wastewater Lab Quality Assurance Manual.
- 4) Working on SLO County HBMP. (Hazardous Business Management Plan).
- 5) SSO event occurred on December 17th, 2011 on Winsor Blvd. SSO was caused by WWTP main breaker failure.
- 6) Repaired WWTP main circuit breaker and Auto Transfer Switch.
- 7) Due to the age and condition of the WWTP main breaker & transfer switch, we are currently looking into upgrading both units.
- 8) Installed new Cellular alarm system at lift station B-4.
- 9) Installed new RACO auto dialer at the WWTP.
- 10) Working on replacing old Dorado phone line alarm system used for monitoring lift station operations. We already successfully installed a CDMA cellular alarm system at lift station B4.
- 11) Repaired pump #1 check valve at Lift station B-4.
- 12) Completed yearly service and oil change on lift station emergency generators.
- 13) Continue to work on developing and updating new Preventive Maintenance Program

Mike Finnigan
Senior WWTP Operator