11-Tanks Design Criteria-HH-06-12-14-V001

Client: CCSD Job No.: Computed By: Hoon Hyung
Project: Emergency Water Supply System Checked By: Date: 6/9/2014

Detail: Tanks Date Checked: Page No.: --

Influent Tank

No. of Duty Tanks	1	
Type of Tank	HDPE	
Nominal Capacity per Tank	5,000	gallons
Tank Diameter, Maximum	10	ft
Tank Sideshell Height, Minimum	10.0	ft
Residence Time at Design Flow	7.5	minutes
Tank Color	Black	

Break/Backwash Tank

1	
HDPE	
10,000	gallons
10	ft
10.0	ft
17.8	minutes
Black	
	HDPE 10,000 10 10.0 17.8


Product Water Tank

No. of Duty Tanks	1	
Type of Tank	HDPE	
Nominal Capacity per Tank	5,000	gallons
Tank Diameter, Maximum	10	ft
Tank Sideshell Height, Minimum	10.0	ft
Residence Time at Design Flow	10.3	minutes
Tank Color	Black	

11-Influent and Product Water Tanks Cutsheet-EY-061114-V001

NON-CONTROLLED COPY


INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE



NON-CONTROLLED COPY

INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE


11-Break Tank Cutsheet-EY-061114-V001



11-AA SHC SA and HPO Tanks Cutsheet-EY-061114-V001


NON-CONTROLLED COPY

INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE




11-CC Tank Cutsheet-EY-061114-V001

NON-CONTROLLED COPY INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE



NON-CONTROLLED COPY

INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE



11-UF System Design Criteria-HH-06-09-14-V001

Client: CCSD Job No.: Computed By: Hoon Hyung
Project: Emergency Water Supply System Checked By: Date: 6/9/2014

Detail: MF System Design Criteria Date Checked: Page No.: --

iner

Type	Auto-Backwash Strainer	
No. of Units	1	units
Strainer Influent Flow	994,466	gpd
	691	gpm
Screen Pore Size, Minimum	300	microns
Strainer Recovery, Minimum	99%	

MF System

MF Influent Flow	984,522	gpd
Wil illident How	684	gpm
MF Influent Pressure	10 to 30	psi
MF Recovery, Minimum	92%	
MF Filtrate Flow	905,760	gpd
Wil Filtrace Flow	629	gpm

MF Membrane

Nominal pore size	0.01	micron
Material	PVDF	
Type/Fiber Flow path	Pressurized/Outside-In	
Manufacturer	Toray	
Model	HFU 2020N	
Membrane Area per Module	775	ft2
Number of Module	38	
Number of MF Train	1	


Operating Conditions


Instantaneous Flux, Maximum	33	gfd
Backwash Interval	20 to 30	minutes
Backwash Duration	2	minutes
Maintenance Wash Interval, Minimum	1	day
CIP Interval, Minimum	30	days


Filtrate Water Quality


Filtrate Turbidity All Time	<0.5	NTU
Filtrate Turbidity 95th Percentile within	<0.2	NTU


a 24 hr Period











11-RO System Design Criteria-HH-06-09-14-V001

Client:	CCSD	Job No.:	Computed By: Hoon Hyung
Project:	Emergency Water Supply System	Checked By:	Date: 6/9/2014
Detail:	RO System Design Criteria	Date Checked:	Page No.: 1 of 3
R	O System		

Total RO Feed Flow	762,261	gpd	529	gpm
RO Recovery, Minimum	92%			
Total RO Permeate Flow	701,280	gpd	487	gpm

Primary RO Train 1

Primary RO 1 Feed Pump

Flow	265	gpm
Head	160	psi
Motor HP	50	hp

Horizontal Centrifugal Pump Type

316 SS Pump Material VFD Yes

Primary RO 1 Booster Pump

Flow	130	gpm
Head	50	psi
Motor HP	7.5	qd

Pump Type Horizontal Centrifugal

316 SS Pump Material VFD Yes

Cartridge Filter

Cartridge filter Influent Flow	265	gpm
Number of Cartridge Filter Vessel	1	
Cartidge Filter Pore Size	5	um

RO Membranes

Material	Composite Polyamide
Configuration	Spiral Wound
Manufacturer	Hydranautics
Model	ESPA4 MAX

Configuration

Number of Stages	2
Stage 1	
Number of Vessels	5
Elements per Vessel	6
Stage 2	
Number of Vessels	3
Elements per Vessel	6
Total Number of Elements	48

Operating Condition

- p		
Stage 1 Flux (average)	15.2	gfd
Stage 2 Flux (average)	13.6	gfd
Stage 1 Flux (lead element)	18.1	gfd
Stage 2 Flux (lead element)	17.4	gfd

11-RO System Design Criteria-HH-06-09-14-V001

Client:	CCSD	Job No.:	Computed By: Hoon Hyung
Project:	Emergency Water Supply System	Checked By:	Date: 6/9/2014
Detail:	RO System Design Criteria	Date Checked:	Page No.: 2 of 3

Primary	/ RO 1	Train 2
r i ii ii ai y		ııaııı 2

RO System Design Criteria	Date Checked:	
rimary RO Train 2		
Primary RO 2 Feed Pump		
Flow	265	gpm
Head	160	psi
Motor HP	50	hp
Pump Type	Horizontal Centrifugal	
Pump Material	316 SS	
VFD	Yes	
Primary RO 2 Booster Pump		
Flow	130	gpm
Head	50	psi
Motor HP	7.5	hp
Pump Type	Horizontal Centrifugal	
Pump Material	316 SS	
VFD	Yes	
Cartridge Filter		
Cartridge filter Influent Flow	265	gpm
Number of Cartridge Filter Vessel	1	
Cartidge Filter Pore Size	5	um
RO Membranes		
Material	Composite Polyamide	
Configuration	Spiral Wound	
Manufacturer	Hydranautics	
Model	ESPA4 MAX	
Configuration		
Number of Stages	2	
Stage 1	_	
Number of Vessels	5	
Elements per Vessel	6	
Stage 2 Number of Vessels	3	
Elements per Vessel	6	
Total Number of Elements	48	
Total Number of Elements	40	
Operating Condition		
Stage 1 Flux (average)	15.2	gfd
Stage 2 Flux (average)	13.6	gfd
Stage 1 Flux (lead element)	18.1	gfd
Stage 2 Flux (lead element)	17.4	gfd

11-RO System Design Criteria-HH-06-09-14-V001

Client:CCSDJob No.:Computed By: Hoon HyungProject:Emergency Water Supply SystemChecked By:Date: 6/9/2014Detail:RO System Design CriteriaDate Checked:Page No.: 3 of 3

Third Stage RO

Third Stage RO Booster Pump

 Flow
 110
 gpm

 Head
 120
 psi

 Motor HP
 15
 hp

Pump Type Horizontal Centrifugal

Pump Material 316 SS VFD Yes

RO Membranes

Material Composite Polyamide
Configuration Spiral Wound
Manufacturer Hydranautics
Model ESPA4 MAX

Configuration

Number of Stages 1

Stage 1

Number of Vessels 3
Elements per Vessel 6
Total Number of Elements 18

Operating Condition

Flux (average) 10.6 gfd Flux (lead element) 23.0 gfd