

COUNTY OF SLO PLANNING AND BUILDING
REVIEWED FOR CODE COMPLIANCE
by Matt Varvel
Project No: PMTC2022-00061 Date: 02/29/2024
The approval of these plans shall not permit
violations of county or state laws.
The County may revoke this permit or require
corrections if they are in error. These
approved plans shall be made available
when inspections are requested.
All changes must be approved.

January 31, 2024
File No. 22-9288
Report No. 21408

Cambria Community Services District
Attn: Tristan Reaper
P.O. Box 65
Cambria, CA 93428

SUBJECT: Proposed Bathroom Structure, Rodeo Grounds Road, Cambria vicinity of S.L.O.C

The construction note 22 shown on the site plan (sheet C300) and the grading plan for the site (sheet C400) prepared by Civil Design Studio, dated January 24, 2024 have been reviewed by Mid-Coast Geotechnical and appear to be in general conformity with the recommendations in our Geotechnical Engineering Report dated November 6, 2022 with the following exception:

- The foundation shall be constructed on a minimum of 12 inches of compacted non-expansive import material placed over scarified and recompacted native material.

It is anticipated that the foundation will bear entirely on certified fill material. We make no representation as to the accuracy of dimensions, measurements, calculations, or any portion of the design.



Respectfully submitted,
MID-COAST Geotechnical, Inc.

Dane C. Jensen
Dane C. Jensen, RCE 60675
Expiration Date 12/31/2024

DCJ:maj
CCSD (e-mail)
Civil Design Studio (e-mail)